

**SERIES PM172EH POWERMETERS
COMMUNICATIONS**

DNP3-2000 Communications Protocol

REFERENCE GUIDE

Every effort has been made to ensure that the material herein is complete and accurate. However, the manufacturer is not responsible for any mistakes in printing or faulty instructions contained in this book. Notification of any errors or misprints will be received with appreciation.

For further information regarding a particular installation, operation or maintenance of equipment, contact the manufacturer or your local representative or distributor.

This book is copyrighted. No part of this book may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, and recording or otherwise without the prior written permission of the manufacturer.

REVISION HISTORY

Rev.A2 (F/W Versions 4.93.2 or later):

1. Added a firmware build number (AI:1023) (see Table 3-4).
2. Added BO Object 10 Variation 1 (see Tables 3-32, A-1).
3. Added DNP points BC:4, BC:5 for kvarh imp/exp energy counters (see Tables 3-1, 3-11).
4. Removed DNP Class 0 group assignments.
5. Event setpoints are configurable for High and Low thresholds and Delta triggers (see Sections “DNP Options Setup” and “DNP Event Setpoints Setup”).

Table of Contents

GENERAL	4
DNP PROTOCOL	5
Introduction	5
PM172EH Deviation from Standard	5
DNP Implementation	5
Scaling Analog Input Objects	6
PM172EH REGISTERS	8
Basic Data Registers	8
Basic Setup Registers	9
User Selectable Options Setup	10
Communications Setup	11
DNP Options Setup	11
DNP Event Setpoints Setup	13
Freeze Requests on Binary Counter Objects.....	14
Resetting Energy, Demands, Counters and Min/Max log	15
Status Registers	15
Alarm Status Registers	16
Extended Data Registers	17
Analog Output Setup	21
Analog Expander Channels Allocation Registers	23
Digital Inputs Allocation Registers	23
Pulsing Setpoints Registers	24
Relay Operation Control	24
Pulse Counter Setup	25
Class 0 Point Assignment	26
APPENDIX A DNP APPLICATION MESSAGES	27
APPENDIX B DNP DEVICE PROFILE	29

1 GENERAL

This document specifies a subset of the DNP3-1999 serial communications protocol used to transfer data between a master computer station and the Series PM172EH Powermeters. The document provides all necessary information for developing third-party communications software capable of communicating with the PM172EH.

Additional information concerning communications operation, configuration of communications parameters, and communications connections is found in the Series PM172EH Installation and Operation Manual.

IMPORTANT

1. The voltage parameters throughout the protocol can represent line-to-neutral or line-to-line voltages depending on the wiring mode selected in the instrument. When the 4LN3 or 3LN3 wiring mode is selected, the voltages will be line-to-neutral; for any other wiring mode, they will be line-to-line voltages. In 4LN3, 4LL3, 3LN3 and 3LL3 wiring modes, harmonic voltages will represent line-to-neutral voltages. In a 3-wire direct connection, harmonic voltages will represent line-to-neutral voltages as they appear on the instrument's input transformers. In a 3-wire open delta connection, harmonic voltages will comprise L12 and L23 line-to-line voltages.
2. In 3-wire connection schemes, the unbalanced current and phase readings for power factor, active power, and reactive power will be zero, because they have no meaning. Only the total three-phase power values can be used.
3. Most of the advanced features are configured using multiple setup parameters that can be accessed in contiguous registers. When writing the setup registers, it is recommended to write all the registers at once using a single request, or to clear (zero) the setup before writing into separate registers. Each written value is checked for compatibility with the other setup parameters, and if the new value does not conform to them, the request will be rejected.

2 DNP PROTOCOL

Introduction

DNP3-1999 (Distributed Network Protocol) is an open standard designed by Harris Control Division. DNP defines a command-response method of communicating digital information between a master and slave device. Detailed information regarding DNP3-1999 is available in the “Basic 4 Document Set” which can be obtained from the DNP User Group. This document describes a LEVEL 2 DNP3-1999 communication protocol implemented between a master station and a slave PM172EH instrument.

PM172EH Deviation from Standard

The PM172EH does not support unsolicited requests or hardware collision avoidance.

The data link layer differs from the Basic 4 specifications because of the master-slave relationship between devices. When the Powermeter receives a request, no further requests can be sent until after the Powermeter makes the appropriate response.

DNP Implementation

Overview

The PM172EH, like most devices, retrieves regular analog and binary data from the instrument by executing directed (non-broadcast) Read requests.

Binary-Output-Status objects and Analog-Output-Status objects are sent with flags that always indicate ONLINE.

A Binary-Output-Status object that indicates the current state of a control digital point (relay) uses remote forced data as well as local forced data bits. The value of a state bit indicates the current state of the digital output point.

The PM172EH executes the parameter clear function and demands resets using the Direct-Operate (or SBO/Operate or Direct-Operate-No-Acknowledge) command to specified points of the Control-Relay-Output-Block object.

Issuing the Direct-Operate (or SBO/Operate or Direct-Operate-No-Acknowledge) command to appropriate points of the Analog-Output-Block object can change the setup parameters. The DNP functions Write, Cold-Restart and Delay Measurement are also supported by the PM172EH. Refer to Appendix A for specific requests and responses. Appendix B contains the standard DNP Device Profile Document.

The Powermeter attempts to respond with the same object variation and qualifier as those in the request. Exceptions to this rule include changing variation 0 to a specific variation and changing qualifier code 6 to 1.

If the Powermeter receives an invalid request, it sets the internal indication to the error code. The following internal indication bits are supported:

Octet Position	Bit Position	Description
0	0	Set when a request received with a broadcast destination address. Cleared after next response.
0	7	Device restart - set when the instrument powers up or after executing Cold Restart, cleared by writing zero to object 80.
0	4	Time-synchronization required from the master. Cleared when master sets the time.
0	5	Set when the instrument is in the Local state(is being programmed via the front panel). Cleared when the instrument is in the Remote state.
1	5	Set when the current configuration in the instrument is corrupted. May also be set as a result of the legal changes in the setup configuration whenever another setup is affected by the changes made. Cleared when either setup is reloaded.

Class 0 Response

The PM172EH DNP implementation supports a wide variety of messages. The most common method to extract DNP static object information is to issue a Read Class-0 request.

There is an option for assigning objects to be polled via Class 0 requests. When this option is used, the Class 0 response includes all static object points specified by the Class 0 Point Assignment Setup (see Table 3-30). By default, the Class 0 Point Assignment setup includes first 32 Analog Input points from Table 3-1, first three Analog Output points from Table 3-2, two Binary Input points represented status inputs, and two Binary Input points represented relay status (see Table 3-13).

Event Objects

The PM172EH allows you to map either static object point onto predefined object change event point for Class 1, Class 2 or Class 3 event polling. A total of 32 points are available for mapping. While DNP static objects can be accessed directly by using the dedicated object point number, the DNP event objects can be generated and accessed only through a mapping mechanism.

You can map any of the 32 mapping points to either Analog Input, Binary Input or Binary Counter object point. By default, those are factory mapped to the first 32 points of the Analog Input object from the Basic Data Registers (see Table 3-1). To re-map these, you must define the required number of points for each allowable DNP object in the DNP Options Setup (see Table 3-8), and then configure each point individually to be polled as an event source, via the DNP Event Setpoints Setup (see Table 3-9). For any mapped static object point, you can enable a corresponding event object point. Note that any changes made to the DNP Options Setup cause a reset of the DNP Event Options Setup points to their defaults.

All event options are disabled by default. Since a mapped static point is configured to create DNP Event objects, events are generated for this point as its value or state changes. Two different scan time rates are used for polling events:

- 200 ms for Binary Counter and Analog Input points;
- 50 ms for Binary Input points.

The memory consumption for keeping events depends on the event objects variation (DNP object size). The maximum buffer size (MBS) per DNP Event Object/ Event Class is 128 byte. The maximum number of events per Class that the instrument can hold can be calculated as follows:

$$\text{Maximum Events Number} = \text{MBS} / (\text{DNP Event Object Size} + 1)$$

For example, the instrument can hold up to 10 measures of the 32-bit Analog Change Event With Time Object: (128 / 12) or up to 16 measures of the 8-bit Binary Change Event With Time Object: (128 / 8).

To disable mapping, explicitly set all registers that specify the number of the Analog Input, Binary Input and/or Binary Counter objects to 0. In this case PM172EH supports Static Operation Polling only.

DNP Address

The instrument on a DNP link must have a unique address. The PM172EH allows one of 256 addresses to be selected. The selectable addresses have a range of 0-255. DNP uses the address 65535 for broadcast function. Note that a broadcast request never generates a DNP response.

Transaction Timing

To allow the master to switch the communication link, the Powermeter minimum response time must be at least 3.5-character time (depending on the baud rate) and at least 5 ms. Table 2-1 shows the actual response time measured at 9600 bps.

Table 2-1 Response Time

No. of Parameters	Typical response time, ms	Maximum response time, ms
1	10	12
5	15	16
10	21	22
43 (Object 30:3)	45	62

Note that Direct-Operate (or SBO/Operate or Direct-Operate-No-Acknowledge) requests for reset/clear registers and setpoint changing are immediately confirmed.

Scaling Analog Input Objects

With the Analog-Input objects, any of variations 1 through 4 can be used. Variations specified in the tables in Section 3 show those that should be used to read a full-range value without a possible over-range error when no scaling is used to accommodate the value to the requested object size.

When over-range occurs, a positive value is reported as 32767 and a negative value as -32768, with the over-range bit being set to 1 in the flag octet if a variation 2 is requested. To avoid over-range errors when a variation 2 or 4 is required, a linear scaling may be used (see Section 3, DNP Options Setup) to scale 32-bit analog readings to 16-bit Analog Input objects. By default, scaling is disabled.

When scaling is enabled, either analog input requested with variation 2 or 4 will be scaled to the range of -32768 to 32767 for bi-directional parameters (such as power and power factor), and to the range of 0 to 32767 for single-ended positive parameters (voltage, current, frequency, etc.). To get a true reading, the reverse conversion should be done using the following formula:

$$Y = ((X - \text{DNP_LO}) \times (\text{HI} - \text{LO})) / (\text{DNP_HI} - \text{DNP_LO}) + \text{LO}$$

where:

- Y - the true reading in engineering units
- X - the raw input data in the range of DNP_LO – DNP_HI
- LO, HI - the data low and high scales in engineering units (specified for each Analog-Input point, see Section 3)
- DNP_LO - DNP low conversion scale: DNP_LO = -32768 for a point with a negative LO scale
DNP_LO = 0 for a point with a zero or positive LO scale
- DNP_HI - DNP high conversion scale: DNP_HI = 32767

EXAMPLE

Suppose you have read a value of 201 for point 3 that contains a current reading (see *Table 3-1*). If your instrument has CT primary current 5000 A, then the current high scale is HI = 2.0×5000 = 10000, and in accordance with the above formula, the current reading in engineering units will be as follows:

$$(201 - 0) \times (10000 - 0) / (32767 - 0) + 0 = 61.34\text{A}$$

3 PM172EH Registers

Basic Data Registers

These registers are used to retrieve a predefined set of the data measured by the Powermeter. All electrical parameters are averaged values over the specified number of real-time measurements.

Table 3-1 Basic Data

Object : Var ⁵	Parameter	Object : Point	Unit ²	Range ¹
30:3	Voltage L1/L12 ⁴	AI:0	V	0 to Vmax
30:3	Voltage L2/L23 ⁴	AI:1	V	0 to Vmax
30:3	Voltage L3/L31 ⁴	AI:2	V	0 to Vmax
30:3	Current L1	AI:3	A	0 to Imax
30:3	Current L2	AI:4	A	0 to Imax
30:3	Current L3	AI:5	A	0 to Imax
30:3	kW L1	AI:6	kW	-Pmax to Pmax
30:3	kW L2	AI:7	kW	-Pmax to Pmax
30:3	kW L3	AI:8	kW	-Pmax to Pmax
30:3	kvar L1	AI:9	kvar	-Pmax to Pmax
30:3	kvar L2	AI:10	kvar	-Pmax to Pmax
30:3	kvar L3	AI:11	kvar	-Pmax to Pmax
30:3	kVA L1	AI:12	kVA	0 to Pmax
30:3	kVA L2	AI:13	kVA	0 to Pmax
30:3	kVA L3	AI:14	kVA	0 to Pmax
30:4	Power factor L1	AI:15	0.001	-999 to 1000
30:4	Power factor L2	AI:16	0.001	-999 to 1000
30:4	Power factor L3	AI:17	0.001	-999 to 1000
30:4	Total Power factor	AI:18	0.001	-999 to 1000
30:3	Total kW	AI:19	kW	-Pmax to Pmax
30:3	Total kvar	AI:20	kvar	-Pmax to Pmax
30:3	Total kVA	AI:21	kVA	0 to Pmax
30:3	Neutral (unbalanced) current	AI:22	A	0 to Imax
30:4	Frequency	AI:23	0.01Hz	0 to 10000
30:3	Maximum sliding window kW demand ³	AI:24	kW	0 to Pmax
30:3	Accumulated kW demand	AI:25	kW	0 to Pmax
30:3	Maximum sliding window kVA demand ³	AI:26	kVA	0 to Pmax
30:3	Accumulated kVA demand	AI:27	kVA	0 to Pmax
30:3	Maximum ampere demand L1	AI:28	A	0 to Imax
30:3	Maximum ampere demand L2	AI:29	A	0 to Imax
30:3	Maximum ampere demand L3	AI:30	A	0 to Imax
30:3	Present sliding window kW demand ³	AI:31	kW	0 to Pmax
30:3	Present sliding window kVA demand ³	AI:32	kVA	0 to Pmax
30:4	PF at maximum kVA (import) window demand	AI:33		0 to 1000
30:4	Voltage THD L1/L12	AI:34	%	0 to 9999
30:4	Voltage THD L2/L23	AI:35	%	0 to 9999
30:4	Voltage THD L3	AI:36	%	0 to 9999
30:4	Current THD L1	AI:37	%	0 to 9999
30:4	Current THD L2	AI:38	%	0 to 9999
30:4	Current THD L3	AI:39	%	0 to 9999
30:4	Current TDD L1	AI:40	%	0 to 1000
30:4	Current TDD L2	AI:41	%	0 to 1000
30:4	Current TDD L3	AI:42	%	0 to 1000
20:5	kWh import	BC:0	kWh	0 to 10 ⁹ -1
20:5	kWh export	BC:1	kWh	0 to 10 ⁹ -1
20:5	kvarh net	BC:2	kvarh	-10 ⁹ +1 to 10 ⁹ -1
20:5	kVAh	BC:3	kVAh	0 to 10 ⁹ -1
20:5	kvarh import ⁶	BC:4	kvarh	0 to 10 ⁹ -1
20:5	kvarh export ⁶	BC:5	kvarh	0 to 10 ⁹ -1

AI indicates Analog-Input point, BC - Binary Counter point.

1 The parameter limits are as follows:

I_{max} ($\times 120\%$ over-range) = $1.2 \times$ CT primary current [A]

Direct wiring (PT Ratio = 1):

V_{max} (690 V input option) = 828.0 V

V_{max} (120 V input option) = 144.0 V

P_{max} = (I_{max} \times V_{max} \times 3) [kW \times 0.001] if wiring mode is 4LN3 or 3LN3

P_{max} = (I_{max} \times V_{max} \times 2) [kW \times 0.001] if wiring mode is 4LL3, 3OP2, 3DIR2, 3OP3 or 3LL3

Wiring via PTs (PT Ratio > 1):

V_{max} (690 V input option) = $144 \times$ PT Ratio [V]

V_{max} (120 V input option) = $144 \times$ PT Ratio [V]

P_{max} = (I_{max} \times V_{max} \times 3)/1000 [MW \times 0.001] if wiring mode is 4LN3 or 3LN3

P_{max} = (I_{max} \times V_{max} \times 2)/1000 [MW \times 0.001] if wiring mode is 4LL3, 3OP2, 3DIR2, 3OP3 or 3LL3

2 When using direct wiring (PT Ratio = 1), voltages are transmitted in 0.1 V units, currents in 0.01 A units, and powers in 0.001 kW/kvar/kVA units. For wiring via PT (PT Ratio > 1), voltages are transmitted in 1V units, currents in 0.01 A units, and powers in 1 kW/kvar/kVA units.

3 To get block interval demand readings, set the number of demand periods equal to 1 (see Table 3-4).

4 When the 4LN3 or 3LN3 wiring mode is selected, the voltages will be line-to-neutral; for any other wiring mode, they will be line-to-line voltages.

5 Variations specified in the table show those that should be used to read a full-range value without a possible over-range error when no scaling is used to accommodate the value to the requested object size (see Section 3, Scaling Analog Input Objects).

6 Available starting with F/W Version 4.93.3 or later.

Basic Setup Registers

These registers are used to access the basic setup parameters. In the event that the modulus field is not equal to 1, the value received from the Powermeter must be multiplied by the modulus. When written, such a number should be divided by the modulus. The basic setup registers (Object 40, Variation 2) are assigned via Class 0 Group Assignment setup by default.

Table 3-2 Basic Setup Registers

Object : Var	Parameter	Object : Point	Range
40:2 (read) 41:2 (write)	Wiring mode ¹	AO:0	0 = 3OP2, 1 = 4LN3, 2 = 3DIR2, 3 = 4LL3, 4 = 3OP3, 5 = 3LN3, 6 = 3LL3
40:1 (read) 41:1 (write)	PT ratio	AO:1	10 to 65000 \times 0.1
40:1 (read) 41:1 (write)	CT primary current	AO:2	1 to 10000 A
40:2 (read) 41:2 (write)	Power demand period	AO:3	1,2,5,10,15,20,30,60 min 255 = external synchronization
40:2 (read) 41:2 (write)	Volt/ampere demand period	AO:4	0 to 1800 sec
40:2 (read) 41:2 (write)	Averaging buffer size	AO:5	8, 16, 32
40:2 (read) 41:2 (write)	Reset enable/disable	AO:6	0 = disable, 1 = enable
40:1 (read)	Reserved	AO:7	Read as 65535
40:2 (read) 41:2 (write)	The number of demand periods	AO:8	1 – 15
40:1 (read)	Reserved	AO:9	Read as 65535
40:1 (read)	Reserved	AO:10	Read as 65535
40:2 (read) 41:2 (write)	Nominal frequency	AO:11	50, 60 Hz
40:2 (read) 41:2 (write)	Maximum demand load current	AO:12	0 to 10000 A (0 = CT primary current)

AO indicates Analog-Output-Status (Read) and Analog-Output-Block (Write) points.

1 The wiring mode options are as follows:

3OP2 - 3-wire open delta using 2 CTs (2 element)

4LN3 - 4-wire WYE using 3 PTs (3 element), line-to-neutral voltage readings

- 3DIR2 - 3-wire direct connection using 2 CTs (2 element)
- 4LL3 - 4-wire WYE using 3 PTs (3 element), line-to-line voltage readings
- 3OP3 - 3-wire open delta using 3 CTs (2 1/2 element)
- 3LN3 - 4-wire WYE using 2 PTs (2 1/2 element), line-to-neutral voltage readings
- 3LL3 - 4-wire WYE using 2 PTs (2 1/2 element), line-to-line voltage readings

User Selectable Options Setup

Table 3-3 User Selectable Options Registers

Object : Var	Parameter	Object : Point	Range
40:2 (read) 41:2 (write)	Power calculation mode	AO:92	0 = using reactive power, 1 = using non-active power
40:2 (read) 41:2 (write)	Energy roll value	AO:93	0 = 1×10^4 1 = 1×10^5 2 = 1×10^6 3 = 1×10^7 4 = 1×10^8 5 = 1×10^9
40:2 (read) 41:2 (write)	Phase energy calculation mode	AO:94	0 = disable, 1 = enable
40:2 (read) 41:2 (write)	Analog output option	AO:95	0 = none 3 = 0-1 mA 1 = 0-20 mA 4 = ± 1 mA 2 = 4-20 mA
40:2 (read) 41:2 (write)	Analog expander output ¹	AO:96	0 = none 3 = 0-1 mA 1 = 0-20 mA 4 = ± 1 mA 2 = 4-20 mA
40:2 (read) 41:2 (write)	Battery option	AO:97	0 = battery OFF, 1 = battery ON

¹ Do not enable the analog expander output if the analog expander is not connected to the instrument, otherwise the computer communications will become garbled.

The registers shown in Table 3-4 are used to retrieve the firmware version number and instrument options.

Table 3-4 Firmware and Instrument Options Registers

Object: Var	Parameter	Object : Point	R/W	Range
30:4	Firmware build number ¹	AI:1023	R	0-65535
30:4	Firmware version number	AI:1024	R	0-65535
30:3	Instrument options 1	AI:1025	R	See Table 3-5
30:3	Instrument options 2	AI:1026	R	See Table 3-5
30:4	Active serial port number	AI:1027	R	0 = Port 1, 1 = Port 2

AI indicates Analog-Input points. Scaling mechanism is not supported for these registers.

¹ Available starting with F/W Version 4.93.2 or later.

Table 3-5 Instrument Options

Options register	Bit number	Description
Options 1 (AI:1025)	0	120V option
	1	690V option
	2-5	Zeros
	6	Analog output 0/4-20 mA
	7	Analog output 0-1 mA
	8	Analog output ± 1 mA
	9	Relays option
	10	Digital inputs option
	11-13	Reserved
	14	Analog expander output ± 1 mA
Options 2 (AI:1026)	15	Reserved
	0-2	Number of relays – 1
	3-6	Number of digital inputs – 1
	7-8	Number of analog outputs – 1
	9-15	Reserved

Communications Setup

These registers are used to access the communications setup parameters.

NOTE

When changing the instrument address, baud rate or data format, the new communications parameters will take effect 100 ms after the instrument responds to the master's request.

Table 3-6 Communications Setup Registers

Port	Object : Var	Parameter	Object : Point	Range
Port #1	40:1 (read) 41:2 (write)	Protocol	AO:64	0 = ASCII 1 = Modbus RTU 3 = DNP3.0
	40:2 (read) 41:2 (write)	Interface	AO:65	0 = RS-232, 1 = RS-422, 2 = RS-485
	40:2 (read) 41:2 (write)	Address	AO:66	0 to 255
	40:2 (read) 41:2 (write)	Baud rate	AO:67	0 = 110 bps 4 = 2400 bps 1 = 300 bps 5 = 4800 bps 2 = 600 bps 6 = 9600 bps 3 = 1200 bps 7 = 19200 bps
	40:2 (read) 41:2 (write)	Data format	AO:68	1 = 8 bits/no parity 2 = 8 bits/even parity
	40:2 (read) 41:2 (write)	Flow control (handshaking)	AO:69	0 = no flow control 1 = software (XON/XOFF) 2 = hardware (CTS)
	40:2 (read) 41:2 (write)	RTS control	AO:70	0 = RTS is not used 1 = RTS is permanently asserted 2 = RTS is controlled by the meter (asserted during the transmission)
Port #2	40:1 (read) 41:2 (write)	Protocol	AO:80	0 = ASCII 1 = Modbus RTU 3 = DNP3.0
	40:2 (read) 41:2 (write)	Interface	AO:81	1 = RS-422, 2 = RS-485
	40:2 (read) 41:2 (write)	Address	AO:82	0 to 255
	40:2 (read) 41:2 (write)	Baud rate	AO:83	0 = 110 bps 4 = 2400 bps 1 = 300 bps 5 = 4800 bps 2 = 600 bps 6 = 9600 bps 3 = 1200 bps 7 = 19200 bps
	40:2 (read) 41:2 (write)	Data format	AO:84	1 = 8 bits/no parity 2 = 8 bits/even parity
	40:1 (read)	Reserved	AO:85	Read as 65535

AO indicates Analog-Output points.

DNP Options Setup

This section describes the general DNP setup registers related to DNP timing and events processing.

The following static objects generate the corresponding DNP change events:

Table 3-7 DNP Static, Frozen and Event Objects

Static Object		Change Object	
Name	Obj : Var	Name	Obj : Var
Single-Bit Binary Input	01:1	Binary Input Change Without Time	02:1
Binary Input With Status	01:2	Binary Input Change With Time	02:2
32-bit: Binary Counter	20:1	32-bit: Counter Change Event Without Time	22:1
Binary Counter Without Flag	20:5	Counter Change Event With Time	22:5
16-bit: Binary Counter	20:2	16-bit: Counter Change Event Without Time	22:2

Static Object		Change Object	
Name	Obj : Var	Name	Obj : Var
Binary Counter Without Flag	20:6	Counter Change Event With Time	22:6
32-bit: Frozen Counter	21:1		
Frozen Counter Without Flag	21:9		
Frozen Counter With Time of Freeze	21:5		
16-bit: Frozen Counter	21:2		
Frozen Counter Without Flag	21:10		
Frozen Counter With Time of Freeze	21:6		
32-bit: Analog Input	30:1	32-bit: Analog Change Event Without Time	32:1
Analog Input Without Flag	30:3	Analog Change Event With Time	32:3
16-bit: Analog Input	30:2	16-bit: Analog Change Event Without Time	32:2
Analog Input Without Flag	30:4	Analog Change Event With Time	32:4

The following registers are used to access the DNP Options Setup parameters. The value range of points 32 to 41 reflects the elements number of the corresponding DNP object/variation list described above. For instance, the default value for the frozen Binary Counter is the Frozen Counter Without Flag obj21var10.

Table 3-8 DNP Options Setup Registers

Object : Var	Parameter	Object : Point	Range
40:2 (read) 41:2 (write)	Binary Input Static	AO:32	0 to 1, 0 by default
40:2 (read) 41:2 (write)	Binary Input Change	AO:33	0 to 1, 1 by default
40:2 (read) 41:2 (write)	Binary Counter	AO:34	0 to 3, 3 by default
40:2 (read) 41:2 (write)	Frozen Binary Counter	AO:35	0 to 5, 4 by default
40:2 (read) 41:2 (write)	Reserved	AO:36	
40:2 (read) 41:2 (write)	Binary Counter Change Event	AO:37	0 to 3, 2 by default
40:2 (read) 41:2 (write)	Analog Input	AO:38	0 to 3, 3 by default
40:2 (read) 41:2 (write)	Reserved	AO:39	
40:2 (read) 41:2 (write)	Reserved	AO:40	
40:2 (read) 41:2 (write)	Analog Input Change Event	AO:41	0 to 3, 2 by default
40:1 (read)	Reserved	AO:42-43	Read as 65535
40:1 (read) 41:2 (write)	DNP Scaling	AO:44	0 – scaling OFF, 1 – scaling ON, by default
40:2 (read) 41:2 (write)	Number mapped points of the Analog Input object ¹	AO:45	0 to 32 (default 32)
40:2 (read) 41:2 (write)	Number mapped points of the Binary Input object ¹	AO:46	0 to 32 (default 0)
40:2 (read) 41:2 (write)	Number mapped points of the Binary Counter object ¹	AO:47	0 to 32 (default 0)
40:2 (read) 41:2 (write)	Select/Operate Timeout	AO:48	2 to 30 seconds (the default 10 seconds)
40:2 (read) 41:2 (write)	Multi Fragment Interval	AO:49	50 to 500 ms (the default 50 ms)
40:2 (read)	Reserved	AO:50-52	Read as 65535
40:2 (read) 41:2 (write)	Time Synch Period	AO:53	1 to 86400 seconds (the default 86400 sec)

AO indicates Analog-Output points.

- The sum of the mapped points cannot exceed the total number of the DNP map space. If the total number of the mapped points equals 0, the report-by-exception mode is not supported.

The Analog Input variation defines the default variation of the Analog Input object that is selected when no specific variation is requested for the Analog Input object by a master station, with the Analog Input object requests using

Qualifier code 06 (variation 0). By default it is set to the 16-bit Analog Input object without flag (object 30, variation 4).

The DNP Scaling is used to control the scaling mechanism. The scaling is turned OFF if this parameter is set to 0. By default this parameter is set to 1 and scaling is ON. Choosing 32-bit Analog Input objects (object 30, variation 1, 3) disables this parameter.

The DNP map space contains 32 event definition register groups (see Table 3-8), which may describe up to 32 points of the static objects: Analog Input, Binary Input and Binary Counter. The points 0 to 31 of the Analog Input object (see Table 3-1) are mapped by the default. The default map does not contain the Binary Input and Binary Counter objects. To re-map the current setting, the user must write new values into points 45-47 of the Analog Output object. If the new values of these parameters are accepted by PM172EH, the new content of the event definition register groups is created automatically. All registers of this group are described below (see Table 3-8). Note here that for every mapped point the object type and sequence number from the range 0 to (number points - 1) are defined automatically. The type of object cannot be changed manually and is defined from the DNP Options Setup Registers only.

The Select Before Operate command causes the PM172EH to start a timer. The Operate command must be received correctly before the value specified by the Select / Operate Timeout parameter expires.

The PM172EH requests time synchs when the time specified by the Time Sync Period parameter has elapsed. The bit 4 of the first octet of the internal indication word is set. The master synchronizes the time by writing the Time and Date object to Powermeter.

DNP Event Setpoints Setup

These registers are used to define the DNP Event Setup parameters.

Table 3-9 DNP Event Definition Registers

DNP Map Group	Object : Var	Register Contents	Object : Point	Range/Scale
#0	40:2(read) 41:2(write)	DNP point number	AO:896	Any actual DNP point number of the selected object ¹
	40:1(read) 41:1(write)	Dead band	AO:897	-2147483848 to 2147483647 (not used for BI change events)
	40:2(read) 41:2(write)	Event option control field	AO:898	See Table 3-10

#31	40:2(read) 41:2(write)	DNP point number	AO:989	Any actual DNP point number of the selected object ¹
	40:2(read) 41:2(write)	Dead band	AO:990	-2147483848 to 2147483647 (not used for BI change events)
	40:2(read) 41:2(write)	Event option control field	AO:991	See Table 3-10

¹ Selected object: Analog Input (AI) or Binary Input (BI) or Binary Counter (BC)

Table 3-10 DNP Event Control Field

Bits	Name	Range
0-1	DNP object	0 = none, 1 = AI change event, 2 = BI change event, 3 = BC change event
2	Object change event scan	0 = disabled, 1 = enabled
3-4	Not used	
5-6	DNP event poll class	0 = Class 1, 1 = Class 2, 2 = Class 3
7	Event log on an event ^{1,2}	0 = disabled, 1 = enabled
8-9	Threshold/Deadband relation	0 = Delta, 1 = More than (over threshold) ¹ , 3 = Less than (under threshold) ¹
10-15	Not used	

¹ Available starting with F/W Version 4.93.2 or later.

² The source of the DNP events recorded to the device Event log is identified as the general Setpoint #17. Either an operating threshold, or deadband should be specified to generate events for numeric (AI and BC) objects, using one of the three allowable relations:

1. Delta – a new event is generated when the absolute value of the difference between the last reported value of the point and its current value exceeds the specified deadband value.
2. More than (Over) - a new event is generated when the point value rises over the specified threshold, and then when the point value returns below the threshold taking into consideration a predefined hysteresis.
3. Less than (Under) - a new event is generated when the point value drops below the specified threshold, and then when the point value returns above the threshold taking into consideration a predefined hysteresis.

A hysteresis for the point return threshold is 0.05 Hz for frequency and 2% of the operating threshold for all other points.

The scan time for binary input change events is 50 ms with a timestamp precision at +/-10 ms. The scan time for analog input and binary counter change events is 200 ms.

Freeze Requests on Binary Counter Objects

Acceptable object variation and qualifier combinations included in the device response are specified in Table 3-7. The Immediate Freeze, Immediate Freeze-No Acknowledgement, Freeze and Clear, Freeze and Clear-No Acknowledgement DNP commands can be applied to all Binary Counters objects supported by the PM172EH. These registers are used to access the Frozen Binary Counters.

Table 3-11 Frozen Binary Counters

Object : Var (Var See Table 3-7)	Parameter	Object : Point	Unit	Value range
Total energies				
21:var	kWh import	FBC:0	kWh	0 to 10 ⁹ -1
21:var	kWh export	FBC:1	kWh	0 to 10 ⁹ -1
21:var	kvarh net	FBC:2	kvarh	-10 ⁹ +1 to 10 ⁹ -1
21:var	kVAh	FBC:3	kVAh	0 to 10 ⁹ -1
21:var	kvarh import ¹	FBC:4	kvarh	0 to 10 ⁹ -1
21:var	kvarh export ¹	FBC:5	kvarh	0 to 10 ⁹ -1
Pulse counters				
21:var	Pulse counter #1	FBC:35328	n/a	0 to 999999
21:var	Pulse counter #2	FBC:35329	n/a	0 to 999999
21:var	Pulse counter #3	FBC:35330	n/a	0 to 999999
21:var	Pulse counter #4	FBC:35331	n/a	0 to 999999
Total energies(Extended Registers)				
21:var	kWh import	FBC:38656	kWh	0 to 10 ⁹ -1
21:var	kWh export	FBC:38657	kWh	0 to 10 ⁹ -1
21:var	Reserved	FBC:38658		0
21:var	Reserved	FBC:38659		0
21:var	kvarh import	FBC:38660	kvarh	0 to 10 ⁹ -1
21:var	kvarh export	FBC:38661	kvarh	0 to 10 ⁹ -1
21:var	Reserved	FBC:38662		0
21:var	Reserved	FBC:38663		0
21:var	kVAh total	FBC:38664	kVAh	0 to 10 ⁹ -1
Phase energies				
21:var	kWh import L1	FBC:38912	kWh	0 to 10 ⁹ -1
21:var	kWh import L2	FBC:38913	kWh	0 to 10 ⁹ -1
21:var	kWh import L3	FBC:38914	kWh	0 to 10 ⁹ -1
21:var	kvarh import L1	FBC:38915	kvarh	0 to 10 ⁹ -1
21:var	kvarh import L2	FBC:38916	kvarh	0 to 10 ⁹ -1
21:var	kvarh import L3	FBC:38917	kvarh	0 to 10 ⁹ -1
21:var	kVAh total L1	FBC:38918	kVAh	0 to 10 ⁹ -1
21:var	kVAh total L2	FBC:38919	kVAh	0 to 10 ⁹ -1
21:var	kVAh total L3	FBC:38920	kVAh	0 to 10 ⁹ -1

¹ Available starting with F/W Version 4.93.2 or later.

FBC - indicates Frozen-Binary-Counter points.

Warning

Any attempt to issue a freeze and clear (or freeze and clear - No acknowledgement) to object 20 variation 0 using function code 0x09 (or 0x10) and the data qualifier 0x06 causes all counters specified in this manual to be reset to zero.

Resetting Energy, Demands, Counters and Min/Max log

The energy value can be reset to zero by issuing the Direct-Operate (or SBO/Operate or Direct-Operate-No-Acknowledge) command using the Control-Relay-Output-Block object to point 0. The request must use the operation Pulse-On. Issuing the same parameters and Direct-Operate (or SBO/Operate or Direct-Operate-No-Acknowledge) command to points 1-3 can reset the maximum demands.

Table 3-12 Reset/Clear Registers

Object : Var	Register function	Object : Point	R/W	Description
10:2 12:1	Clear total energy registers	BO:0 CROB:0	Read Write	Return zero PULSE ON
10:2 12:1	Clear total maximum demand registers (all demands)	BO:1 CROB:1	Read Write	Return zero PULSE ON
10:2 12:1	Clear power demands	BO:2 CROB:2	Read Write	Return zero PULSE ON
10:2 12:1	Clear volt/ampere demands	BO:3 CROB:3	Read Write	Return zero PULSE ON
10:2 12:1	Reserved	BO:4-11 CROB:4-11	Read Write	Return zero
10:2 12:1	Clear pulse counters (all counters)	BO:12 CROB:12	Read Write	Return zero PULSE ON
10:2 12:1	Clear pulse counter #1	BO:13 CROB:13	Read Write	Return zero PULSE ON
10:2 12:1	Clear pulse counter #2	BO:14 CROB:14	Read Write	Return zero PULSE ON
10:2 12:1	Clear pulse counter #3	BO:15 CROB:15	Read Write	Return zero PULSE ON
10:2 12:1	Clear pulse counters #4	BO:16 CROB:16	Read Write	Return zero PULSE ON
10:2 12:1	Reserved	BO:17-20 CROB:17-20	Read Write	Return zero
10:2 12:1	Clear Min/Max log	BO:21 CROB:21	Read Write	Return zero PULSE ON

BO indicates Binary Output Status. CROB indicates Control-Relay-Output-Block point.

The following restriction should be noted when using object 12 to control the listed points.

- ♦ The Count byte is ignored. The Control Code byte is checked for the following:
 - Pulse On (1) is valid for all points; other codes are invalid and will be rejected.
- ♦ The On Time and Off Time fields are ignored.
- ♦ The status byte in the response will reflect the success or failure of the control operation:
 - Request Accepted (0) will be returned if the command was accepted;
 - Request not Accepted due to Formatting Errors (3) will be returned if the Control Code byte was incorrectly formatted or if an invalid code was present in the command;
 - Control Operation not Supported for this Point (4) will be returned if the Control Point was out of control (for instance, reset is disabled via Basic Setup).

Issuing the same parameters and Direct-Operate (or SBO/Operate or Direct-Operate-No-Acknowledge) command to points 12-16 can clear the Pulse Counters.

Issuing the same parameters and Direct-Operate (or SBO/Operate or Direct-Operate-No-Acknowledge) command to point 21 can reset the Min/Max log.

Status Registers

These registers are used to retrieve the status of digital input/output points (hardware or software) from the instrument.

Table 3-13 Status Registers (Read)

Object : Var	Description	Object : Point	Bit meaning
01:1	Relay #1 status	BI:0	Relay status:
01:1	Relay #2 status	BI:1	0 = released, 1 = operated
01:1	Status input #1	BI:16	Contact: 0 = open, 1 = closed
01:1	Status input #2	BI:17	
01:1	Battery status	BI:48	0 = low, 1 = normal

BI indicates Single-Bit Binary-Input points (Read).

Alarm Status Registers

These registers are used to retrieve the status alarm parameters from the instrument.

NOTE

The PM172EH provides the self-check alarm register.

The self-check alarm points indicate possible problems with the instrument hardware or setup configuration. The hardware problems are indicated by the appropriate points, which are set whenever the instrument fails self-test diagnostics, or in the event of loss of power. The dedicated binary point indicates the setup configuration problems, which is set when either configuration register is corrupted. In this event, the instrument will use the default configuration. The configuration corrupt bit may also be set as a result of the legal changes in the setup configuration since the instrument might implicitly change or clear other setups if they are affected by the changes made.

Issuing the Direct-Operate (or SBO/Operate or Direct-Operate-No-Acknowledge) command using the Control-Relay-Output-Block object (with the code operation Latch-Off) to points 64-75 can reset hardware fault points. The configuration corrupt status point is also reset automatically when you change setup either via the front panel or through communications.

Table 3-14 Alarm Status Registers

Object : Var	Description	Object : Point	Bit meaning
	Self-check Alarm Register		1 = alarm has been asserted 0 = alarm hasn't been asserted
10:2(read) 12:1(write)	Reserved	B0:64 CROB:64	Reading returns 0
10:2(read) 12:1(write)	ROM error	B0:65 CROB:65	
10:2(read) 12:1(write)	RAM error	B0:66 CROB:66	
10:2(read) 12:1(write)	Watchdog timer reset	B0:67 CROB:67	
10:2(read) 12:1(write)	Sampling failure	B0:68 CROB:68	
10:2(read) 12:1(write)	Out of control trap	B0 :69 CROB:69	
10:2(read) 12:1(write)	Reserved	BI :70 CROB:70	Reading returns 0
10:2(read) 12:1(write)	Timing failure	B0 :71 CROB:71	
10:2(read) 12:1(write)	Loss of power (power up)	B0:72 CROB:72	
10:2(read) 12:1(write)	External reset (Cold Restart) ¹	B0:73 CROB:73	
10:2(read) 12:1(write)	Configuration corrupted ¹	B0:74 CROB:74	
10:2(read) 12:1(write)	Time synchronization required ¹	B0:75 CROB:75	
10:2(read) 12:1(write)	Low battery ²	B0:76 CROB:76	
10:2(read) 12:1(write)	Reserved	77-79 77-79	Reading returns 0

BO indicates Binary-Output -Status (Read) or Control-Relay-Output Block (Write) points.

¹ These self-check alarms are doubled with the corresponding internal indication bits.

² Available starting with F/W Version 4.93.2 or later.

The following restrictions should be noted when using Object 12 to control the listed points:

- ♦ The Count byte is ignored.
- ♦ The Control Code byte is checked:
 - Latch Off is valid for all points; other codes are invalid and will be rejected.
- ♦ The On Time and Off Time fields are ignored.
- ♦ The status byte in the response will reflect the success or failure of the control operation:
 - Request Accepted (0) will be return if the command was accepted;
 - Request not Accepted due to Formatting Errors (3) will be returned if the Control Code byte was incorrectly formatted or if an invalid Code was present in the command.

Extended Data Registers

These registers are used to retrieve any data measured by the instrument. A list of the extended data parameters, their points and value ranges are shown in Table 3-15.

Table 3-15 Extended Data Registers

Obj.: Var. ⁶	Parameter	Object: Point	Unit ²	Value, Range ¹	Comment
30:4	None	AI:32768	n/a	0	
Status inputs					
01:1	Status input #1	BI:34304	n/a	0/1	
01:1	Status input #2	BI:34305	n/a	0/1	
Relay status					
01:1	Relay #1 status	BI:34816	n/a	0/1	
01:1	Relay #2 status	BI:34817	n/a	0/1	
Pulse counters					
20:5	Pulse counter #1	BC:35328	n/a	0 to 999999	
20:5	Pulse counter #2	BC:35329	n/a	0 to 999999	
20:5	Pulse counter #3	BC:35330	n/a	0 to 999999	
20:5	Pulse counter #4	BC:35331	n/a	0 to 999999	
Real-time values per phase					
30:3	Voltage L1/L12 ⁵	AI:35840	0.1V/1V	0 to Vmax	
30:3	Voltage L2/L23 ⁵	AI:35841	0.1V/1V	0 to Vmax	
30:3	Voltage L3/L31 ⁵	AI:35842	0.1V/1V	0 to Vmax	
30:3	Current L1	AI:35843	0.01A/1A	0 to Imax	
30:3	Current L2	AI:35844	0.01A/1A	0 to Imax	
30:3	Current L3	AI:35845	0.01A/1A	0 to Imax	
30:3	kW L1	AI:35846	0.001kW/1kW	-Pmax to Pmax	
30:3	kW L2	AI:35847	0.001kW/1kW	-Pmax to Pmax	
30:3	kW L3	AI:35848	0.001kW/1kW	-Pmax to Pmax	
30:3	kvar L1	AI:35849	0.001kvar/1kvar	-Pmax to Pmax	
30:3	kvar L2	AI:35850	0.001kvar/1kvar	-Pmax to Pmax	
30:3	kvar L3	AI:35851	0.001kvar/1kvar	-Pmax to Pmax	
30:3	kVA L1	AI:35852	0.001kVA/1kVA	0 to Pmax	
30:3	kVA L2	AI:35853	0.001kVA/1kVA	0 to Pmax	
30:3	kVA L3	AI:35854	0.001kVA/1kVA	0 to Pmax	
30:4	Power factor L1	AI:35855	0.001	-999 to 1000	× 0.001
30:4	Power factor L2	AI:35856	0.001	-999 to 1000	× 0.001
30:4	Power factor L3	AI:35857	0.001	-999 to 1000	× 0.001
30:4	Voltage THD L1/L12	AI:35858	0.1%	0 to 9999	×0.1
30:4	Voltage THD L2/L23	AI:35859	0.1%	0 to 9999	×0.1
30:4	Voltage THD L3	AI:35860	0.1%	0 to 9999	×0.1
30:4	Current THD L1	AI:35861	0.1%	0 to 9999	×0.1
30:4	Current THD L2	AI:35862	0.1%	0 to 9999	×0.1
30:4	Current THD L3	AI:35863	0.1%	0 to 9999	×0.1
30:4	K-Factor L1	AI:35864	0.1	10 to 9999	×0.1
30:4	K-Factor L2	AI:35865	0.1	10 to 9999	×0.1
30:4	K-Factor L3	AI:35866	0.1	10 to 9999	×0.1

Obj.: Var. 6	Parameter	Object: Point	Unit 2	Value, Range ¹	Comment
30:4	Current TDD L1	AI:35867	0.1%	0 to 1000	×0.1
30:4	Current TDD L2	AI:35868	0.1%	0 to 1000	×0.1
30:4	Current TDD L3	AI:35869	0.1%	0 to 1000	×0.1
30:3	Voltage L12	AI:35870	0.1V/1V	0 to Vmax	
30:3	Voltage L23	AI:35871	0.1V/1V	0 to Vmax	
30:3	Voltage L31	AI:35872	0.1V/1V	0 to Vmax	
Real-time total values					
30:3	Total kW	AI:36608	0.001kW/1kW	-Pmax to Pmax	
30:3	Total kvar	AI:36609	0.001kvar/1kvar	-Pmax to Pmax	
30:3	Total kVA	AI:36610	0.001kVA/1kVA	0 to Pmax	
30:4	Total PF	AI:36611	0.001	-999 to 1000	×0.001
30:4	Reserved	AI:36612	n/a	0	
30:4	Reserved	AI:36613	n/a	0	
Real-time auxiliary values					
30:4	Reserved	AI:36864		0	
30:3	Neutral current	AI:36865	0.01A	0 to Imax	
30:4	Frequency ³	AI:36866	0.01Hz	0 to 10000	×0.01
30:4	Voltage unbalance	AI:36867	1%	0 to 300	
30:4	Current unbalance	AI:36868	1%	0 to 300	×0.01
Average values per phase					
30:3	Voltage L1/L12 ⁵	AI:37120	0.1V/1V	0 to Vmax	
30:3	Voltage L2/L23 ⁵	AI:37121	0.1V/1V	0 to Vmax	
30:3	Voltage L3/L31 ⁵	AI:37122	0.1V/1V	0 to Vmax	
30:3	Current L1	AI:37123	0.01A/1A	0 to Imax	
30:3	Current L2	AI:37124	0.01A/1A	0 to Imax	
30:3	Current L3	AI:37125	0.01A/1A	0 to Imax	
30:3	kW L1	AI:37126	0.001kW/1kW	-Pmax to Pmax	
30:3	kW L2	AI:37127	0.001kW/1kW	-Pmax to Pmax	
30:3	kW L3	AI:37128	0.001kW/1kW	-Pmax to Pmax	
30:3	kvar L1	AI:37129	0.001kvar/1kvar	-Pmax to Pmax	
30:3	kvar L2	AI:37130	0.001kvar/1kvar	-Pmax to Pmax	
30:3	kvar L3	AI:37131	0.001kvar/1kvar	-Pmax to Pmax	
30:3	kVA L1	AI:37132	0.001kVA/1kVA	0 to Pmax	
30:3	kVA L2	AI:37133	0.001kVA/1kVA	0 to Pmax	
30:3	kVA L3	AI:37134	0.001kVA/1kVA	0 to Pmax	
30:4	Power factor L1	AI:37135	0.001	-999 to 1000	×0.001
30:4	Power factor L2	AI:37136	0.001	-999 to 1000	×0.001
30:4	Power factor L3	AI:37137	0.001	-999 to 1000	×0.001
30:4	Voltage THD L1/L12	AI:37138	0.1%	0 to 9999	×0.1
30:4	Voltage THD L2/L23	AI:37139	0.1%	0 to 9999	×0.1
30:4	Voltage THD L3	AI:37140	0.1%	0 to 9999	×0.1
30:4	Current THD L1	AI:37141	0.1%	0 to 9999	×0.1
30:4	Current THD L2	AI:37142	0.1%	0 to 9999	×0.1
30:4	Current THD L3	AI:37143	0.1%	0 to 9999	×0.1
30:4	K-Factor L1	AI:37144	0.1	10 to 9999	×0.1
30:4	K-Factor L2	AI:37145	0.1	10 to 9999	×0.1
30:4	K-Factor L3	AI:37146	0.1	10 to 9999	×0.1
30:4	Current TDD L1	AI:37147	0.1%	0 to 1000	×0.1
30:4	Current TDD L2	AI:37148	0.1%	0 to 1000	×0.1
30:4	Current TDD L3	AI:37149	0.1%	0 to 1000	×0.1
30:3	Voltage L12	AI:37150	0.1V/1V	0 to Vmax	
30:3	Voltage L23	AI:37151	0.1V/1V	0 to Vmax	
30:3	Voltage L31	AI:37152	0.1V/1V	0 to Vmax	
Average total values					
30:3	Total kW	AI:37888	0.001kW/1kW	-Pmax to Pmax	
30:3	Total kvar	AI:37889	0.001kvar/1kvar	-Pmax to Pmax	
30:3	Total kVA	AI:37890	0.001kVA/1kVA	0 to Pmax	
30:4	Total PF	AI:37891	0.001	-999 to 1000	×0.001
30:4	Reserved	AI:37892		0	
30:4	Reserved	AI:37893		0	
Average auxiliary values					
30:4	Reserved	AI:38144		0	
30:3	Neutral current	AI:38145	0.01A	0 to Imax	

Obj.: Var. ⁶	Parameter	Object: Point	Unit ²	Value, Range ¹	Comment
30:4	Frequency ³	AI:38146	0.01Hz	0 to 10000	×0.01
30:4	Voltage unbalance	AI:38147	1%	0 to 300	
30:4	Current unbalance	AI:38148	1%	0 to 300	×0.01
Present demands					
30:3	Volt demand L1/L12 ⁵	AI:38400	0.1V/1V	0 to Vmax	
30:3	Volt demand L2/L23 ⁵	AI:38401	0.1V/1V	0 to Vmax	
30:3	Volt demand L3/L31 ⁵	AI:38402	0.1V/1V	0 to Vmax	
30:3	Ampere Demand L1	AI:38403	0.01A	0 to Imax	
30:3	Ampere Demand L2	AI:38404	0.01A	0 to Imax	
30:3	Ampere Demand L3	AI:38405	0.01A	0 to Imax	
30:3	Block kW import demand	AI:38406	0.001kW/1kW	0 to Pmax	
30:3	Block kvar import demand	AI:38407	0.001kvar/1kvar	0 to Pmax	
30:3	Block kVA demand	AI:38408	0.001kVA/1kVA	0 to Pmax	
30:3	Sliding window kW import demand	AI:38409	0.001kW/1kW	0 to Pmax	
30:3	Sliding window kvar import demand	AI:38410	0.001kvar/1kar	0 to Pmax	
30:3	Sliding window kVA demand	AI:38411	0.001kVA/1kVA	0 to Pmax	
30:4	Reserved	AI:38412		0	
30:4	Reserved	AI:38413		0	
30:4	Reserved	AI:38414		0	
30:3	Accumulated kW import demand	AI:38415	0.001kW/1kW	0 to Pmax	
30:3	Accumulated kvar import demand	AI:38416	0.001kvar/1kvar	0 to Pmax	
30:3	Accumulated kVA demand	AI:38417	0.001kVA/1kVA	0 to Pmax	
30:3	Predicted sliding window kW import demand	AI:38418	0.001kW/1kW	0 to Pmax	
30:3	Predicted sliding window kvar import demand	AI:38419	0.001kvar/1kvar	0 to Pmax	
30:3	Predicted sliding window kVA demand	AI:38420	0.001kVA/1kVA	0 to Pmax	
30:4	PF (import) at maximum sliding window kVA demand	AI:38421	0.001	0 to 1000	× 0.001
30:3	Block kW export demand	AI:38422	0.001kW/1kW	0 to Pmax	
30:3	Block kvar export demand	AI:38423	0.001kvar/1kvar	0 to Pmax	
30:3	Sliding window kW export demand	AI:38424	0.001kW/1kW	0 to Pmax	
30:3	Sliding window kvar export demand	AI:38425	0.001kvar/1kvar	0 to Pmax	
30:3	Accumulated kW export demand	AI:38426	0.001kW/1kW	0 to Pmax	
30:3	Accumulated kvar export demand	AI:38427	0.001kvar/1kvar	0 to Pmax	
30:3	Predicted sliding window kW export demand	AI:38428	0.001kW/1kW	0 to Pmax	
30:3	Predicted sliding window kvar export demand	AI:38429	0.001kvar/1kvar	0 to Pmax	
Total energies					
20:5	kWh import	BC:38656	kWh	0 to 10 ⁹ -1	
20:5	kWh export	BC:38657	kWh	0 to 10 ⁹ -1	
20:5	Reserved	BC:38658		0	
20:5	Reserved	BC:38659		0	
20:5	kvarh import	BC:38660	kvarh	0 to 10 ⁹ -1	
20:5	kvarh export	BC:38661	kvarh	0 to 10 ⁹ -1	
20:5	Reserved	BC:38662		0	
20:5	Reserved	BC:38663		0	
20:5	kVAh total	BC:38664	kVAh	0 to 10 ⁹ -1	
Phase energies					
20:5	kWh import L1	BC:38912	kWh	0 to 10 ⁹ -1	
20:5	kWh import L2	BC:38913	kWh	0 to 10 ⁹ -1	
20:5	kWh import L3	BC:38914	kWh	0 to 10 ⁹ -1	
20:5	kvarh import (inductive) L1	BC:38915	kvarh	0 to 10 ⁹ -1	
20:5	kvarh import (inductive) L2	BC:38916	kvarh	0 to 10 ⁹ -1	
20:5	kvarh import (inductive) L3	BC:38917	kvarh	0 to 10 ⁹ -1	
20:5	kVAh total L1	BC:38918	kVAh	0 to 10 ⁹ -1	
20:5	kVAh total L2	BC:38919	kVAh	0 to 10 ⁹ -1	
20:5	kVAh total L3	BC:38920	kVAh	0 to 10 ⁹ -1	
Fundamental (H01) real-time values per phase					
30:3	Voltage L1/L12	AI:43264	0.1V/1 V	0 to Vmax	
30:3	Voltage L2/L23	AI:43265	0.1V/1 V	0 to Vmax	

Obj.: Var. 6	Parameter	Object: Point	Unit 2	Value, Range ¹	Comment
30:3	Voltage L3/L31	AI:43266	0.1V/1 V	0 to Vmax	
30:3	Current L1	AI:43267	0.01A/1A	0 to Imax	
30:3	Current L2	AI:43268	0.01A/1A	0 to Imax	
30:3	Current L3	AI:43269	0.01A/1A	0 to Imax	
30:3	kW L1	AI:43270	0.001kW/1kW	-Pmax to Pmax	
30:3	kW L2	AI:43271	0.001kW/1kW	-Pmax to Pmax	
30:3	kW L3	AI:43272	0.001kW/1kW	-Pmax to Pmax	
30:3	kvar L1	AI:43273	0.001kvar/1kvar	-Pmax to Pmax	
30:3	kvar L2	AI:43274	0.001kvar/1kvar	-Pmax to Pmax	
30:3	kvar L3	AI:43275	0.001kvar/1kvar	-Pmax to Pmax	
30:3	kVA L1	AI:43276	0.001kVA/1kVA	0 to Pmax	
30:3	kVA L2	AI:43277	0.001kVA/1kVA	0 to Pmax	
30:3	kVA L3	AI:43278	0.001kVA/1kVA	0 to Pmax	
30:4	Power factor L1	AI:43279	0.001	-999 to 1000	×0.001
30:4	Power factor L2	AI:43280	0.001	-999 to 1000	×0.001
30:4	Power factor L3	AI:43281	0.001	-999 to 1000	×0.001
Fundamental (H01) real-time total values					
30:3	Total kW	AI:43520	0.001kW/1kW	-Pmax to Pmax	
30:3	Total kvar	AI:43521	0.001kvar/1kvar	-Pmax to Pmax	
30:3	Total kVA	AI:43522	0.001kVA/1kVA	0 to Pmax	
30:4	Total PF	AI:43523	0.001	-999 to 1000	×0.001
Minimum real-time values per phase (M)					
30:3	Voltage L1/L12 ⁵	AI:44032	0.1V/1V	0 to Vmax	
30:3	Voltage L2/L23 ⁵	AI:44033	0.1V/1V	0 to Vmax	
30:3	Voltage L3/L31 ⁵	AI:44034	0.1V/1V	0 to Vmax	
30:3	Current L1	AI:44035	0.01A	0 to Imax	
30:3	Current L2	AI:44036	0.01A	0 to Imax	
30:3	Current L3	AI:44037	0.01A	0 to Imax	
Minimum real-time total values (M)					
30:3	Total kW	AI:44288	0.001kW/1kW	-Pmax to Pmax	
30:3	Total kvar	AI:44289	0.001kvar/1kvar	-Pmax to Pmax	
30:3	Total kVA	AI:44290	0.001kVA/1kVA	0 to Pmax	
30:4	Total PF ⁴	AI:44291	0.001	-999 to 1000	×0.001
Minimum real-time auxiliary values (M)					
30:4	Reserved	AI:44544		0	
30:3	Neutral current	AI:44545	0.01A	0 to Imax	
30:4	Frequency ³	AI:44546	0.01Hz	0 to 10000	×0.01
Minimum demands (M)					
30:4	Reserved	AI:44800- AI:44816		0	
Maximum real-time values per phase (M)					
30:3	Voltage L1/L12 ⁵	AI:46080	0.1V/1V	0 to Vmax	
30:3	Voltage L2/L23 ⁵	AI:46081	0.1V/1V	0 to Vmax	
30:3	Voltage L3/L31 ⁵	AI:46082	0.1V/1V	0 to Vmax	
30:3	Current L1	AI:46083	0.01A	0 to Imax	
30:3	Current L2	AI:46084	0.01A	0 to Imax	
30:3	Current L3	AI:46085	0.01A	0 to Imax	
Maximum real-time total values (M)					
30:3	Total kW	AI:46336	0.001kW/1kW	-Pmax to Pmax	
30:3	Total kvar	AI:46337	0.001kvar/1kvar	-Pmax to Pmax	
30:3	Total kVA	AI:46338	0.001kVA/1kVA	0 to Pmax	
30:4	Total PF ⁴	AI:46339	0.001	-999 to 1000	×0.001
Maximum real-time auxiliary values (M)					
30:4	Reserved	AI:46592		0	
30:3	Neutral current	AI:46593	0.01A	0 to Imax	
30:4	Frequency ³	AI:46594	0.01Hz	0 to 10000	×0.01
Maximum demands (M)					
30:3	Max. volt demand L1/L12 ⁵	AI:46848	0.1V/1V	0 to Vmax	
30:3	Max. volt demand L2/L23 ⁵	AI:46849	0.1V/1V	0 to Vmax	
30:3	Max. volt demand L3/L31 ⁵	AI:46850	0.1V/1V	0 to Vmax	
30:3	Max. ampere demand L1	AI:46851	0.01A	0 to Imax	
30:3	Max. ampere demand L2	AI:46852	0.01A	0 to Imax	
30:3	Max. ampere demand L3	AI:46853	0.01A	0 to Imax	

Obj.: Var. ⁶	Parameter	Object: Point	Unit ²	Value, Range ¹	Comment
30:4	Reserved	AI:46854		0	
30:4	Reserved	AI:46855		0	
30:4	Reserved	AI:46856		0	
30:3	Max. sliding window kW import demand	AI:46857	0.001kW/1kW	0 to Pmax	
30:3	Max. sliding window kvar import demand	AI:46858	0.001kvar/1kvar	0 to Pmax	
30:3	Max. sliding window kVA demand	AI:46859	0.001kVA/1kVA	0 to Pmax	
30:4	Reserved	AI:46860		0	
30:4	Reserved	AI:46861		0	
30:4	Reserved	AI:46862		0	
30:3	Max. sliding window kW export demand	AI:46863	0.001kW/1kW	0 to Pmax	
30:3	Max. sliding window kvar export demand	AI:46864	0.001kvar/1kvar	0 to Pmax	

¹ For the parameter limits, see Note ¹ to Table 3-1.

² When using direct wiring (PT Ratio = 1), voltages are transmitted in 0.1V units, currents in 0.01A units, and powers in 0.001 kW/kvar/kVA units. For wiring via PT (PT Ratio > 1), voltages are transmitted in 1V units, currents in 0.01A units, and powers in 1 kW/kvar/kVA units.

³ The actual frequency range is 45.00 - 65.00 Hz.

⁴ Absolute Min/Max value (lag or lead).

⁵ When the 4LN3 or 3LN3 wiring mode is selected, the voltages will be line-to-neutral; for any other wiring mode, they will be line-to-line voltages.

⁶ Variations specified in the table show those that should be used to read a full-range value without a possible over-range error when no scaling is used to accommodate the value to the requested object size (see Section 3, Scaling Analog Input Objects).

(M) These parameters are logged to the Min/Max log.

Analog Output Setup

These registers are used to obtain or change the allocation of the internal multiplexed analog output channels. For the output parameters that can be selected see Table 3-18.

Table 3-16 Analog Output Allocation Registers

Channel	Points
Channel #1	192-194
Channel #2	195-197

Table 3-17 Analog Channel Allocation Registers

Channel	Object : Var	Register contents	Object : Point	Range/Scale
#1	40:2(read) 41:2(write)	Output parameter ID	AO:192	See Table 3-18
	40:1(read) 41:1(write)	Zero scale (0/4 mA)	AO:193	
	40:1(read) 41:1(write)	Full scale (20/1 mA)	AO:194	
#2	40:2(read) 41:2(write)	Output parameter ID	AO:195	See Table 3-18
	40:1(read) 41:1(write)	Zero scale (0/4 mA)	AO:196	
	40:1(read) 41:1(write)	Full scale (20/1 mA)	AO:197	

NOTES

- Except for the signed power factor (see Note 3 to Table 3-18), the output scale is linear within the value range. The scale range will be inverted if the full scale specified is less than the zero scale.
- For bi-directional analog output (± 1 mA), the zero scale corresponds to the center of the scale range (0 mA) and the direction of current matches the sign of the output parameter. For signed (bi-directional) values, such as powers and signed power factor, the scale is always symmetrical with regard to 0 mA, and the full scale corresponds to +1 mA output

for positive readings and to -1 mA output for negative readings. For these, the zero scale (0 mA output) is permanently set in the instrument to zero for all parameters except of signed power factor for which it is set to 1.000. In the write request, the zero scale is ignored. No error will occur when you attempt to change it. Unsigned parameters are output within the current range 0 to +1 mA and can be scaled using both zero and full scales as in the event of single-ended analog output.

Table 3-18 Analog Output Parameters

Parameter	ID	Unit ²	Scale/Range ¹	Modulus
None	0	n/a	0	
Real-time values per phase				
Voltage L1/L12 ⁵	3072	0.1V/1V	0 to Vmax	
Voltage L2/L23 ⁵	3073	0.1V/1V	0 to Vmax	
Voltage L3/L31 ⁵	3074	0.1V/1V	0 to Vmax	
Current L1	3075	0.01A	0 to Imax	
Current L2	3076	0.01A	0 to Imax	
Current L3	3077	0.01A	0 to Imax	
Real-time total values				
Total kW	3840	0.001kW/1kW	-Pmax to Pmax	
Total kvar	3841	0.001kvar/1kvar	-Pmax to Pmax	
Total kVA	3842	0.001kVA/1kVA	0 to Pmax	
Total PF ⁴	3843	0.001	-999 to 1000	×0.001
Total PF lag	3844	0.001	-999 to 1000	×0.001
Total PF lead	3845	0.001	-999 to 1000	×0.001
Real-time auxiliary values				
Frequency ³	4098	0.01Hz	0 to 10000	×0.01
Average values per phase				
Voltage L1/L12 ⁵	4352	0.1V/1V	0 to Vmax	
Voltage L2/L23 ⁵	4353	0.1V/1V	0 to Vmax	
Voltage L3/L31 ⁵	4354	0.1V/1V	0 to Vmax	
Current L1	4355	0.01A	0 to Imax	
Current L2	4356	0.01A	0 to Imax	
Current L3	4357	0.01A	0 to Imax	
Average total values				
Total kW	5120	0.001kW/1kW	-Pmax to Pmax	
Total kvar	5121	0.001kvar/1kvar	-Pmax to Pmax	
Total kVA	5122	0.001kVA/1kVA	0 to Pmax	
Total PF ⁴	5123	0.001	-999 to 1000	×0.001
Total PF lag	5124	0.001	-999 to 1000	×0.001
Total PF lead	5125	0.001	-999 to 1000	×0.001
Average auxiliary values				
Neutral current	5377	0.01A	0 to Imax	
Frequency ³	5378	0.01Hz	0 to 10000	×0.01
Present demands				
Accumulated kW import demand	5647	0.001kW/1kW	0 to Pmax	
Accumulated kvar import demand	5648	0.001kvar/1kvar	0 to Pmax	
Accumulated kVA demand	5649	0.001kVA/1kVA	0 to Pmax	
Accumulated kW export demand	5658	0.001kW/1kW	0 to Pmax	
Accumulated kvar export demand	5659	0.001kvar/1kvar	0 to Pmax	

¹ For the parameter limits, see Note ¹ to Table 4.1.

² When using direct wiring (PT Ratio = 1), voltages are transmitted in 0.1V units, currents in 0.01A units, and powers in 0.001 kW/kvar/kVA units. For wiring via PTs (PT Ratio > 1), voltages are transmitted in 1V units, currents in 0.01A units, and powers in 1 kW/kvar/kVA units.

³ The actual frequency range is 45.00 to 65.00 Hz

⁴ The output scale for signed (bi-directional) power factor is symmetrical with regard to ±1.000 and is linear from -0 to -1.000, and from 1.000 to +0 (note that -1.000 ≡ +1.000). Negative power factor is output as [-1.000 minus measured value], and non-negative power factor is output as [+1.000 minus measured value]. To define the entire range for power factor from -0 to +0, the scales would be specified as -0/0. Because a negative zero may not be transmitted, the value of -0.001 is used to specify the scale of -0, and both +0.001 and 0.000 are used to specify the scale of +0. To define the range of -0 to 0, you must send -1/1 or -1/0 (considering the modulus of ×0.001).

⁵ When the 4LN3 or 3LN3 wiring mode is selected, the voltages will be line-to-neutral; for any other wiring mode they will be line-to-line voltages.

Analog Expander Channels Allocation Registers

These registers are used to obtain or change the allocation of the analog expander channels. For the output parameters that can be selected see Table 3-18.

Table 3-19 Analog Expander Allocation Registers

Channel	Points	Channel	Points
Channel #1	256-258	Channel #9	280-282
Channel #2	259-261	Channel #10	283-285
Channel #3	262-264	Channel #11	286-288
Channel #4	265-267	Channel #12	289-291
Channel #5	268-270	Channel #13	292-294
Channel #6	271-273	Channel #14	295-297
Channel #7	274-276	Channel #15	298-300
Channel #8	277-279	Channel #16	301-303

Table 3-20 Analog Expander Channel Allocation Registers

Channel	Object : Var	Register contents	Object : Point	Range/Scale
#1	40:2(read) 41:2(write)	Output parameter ID	AO:256	See Table 3-18
	40:1(read) 41:1(write)	Zero scale (0/4 mA)	AO:257	
	40:1(read) 41:1(write) ...	Full scale (20 mA)	AO:258	
#16	40:2(read) 41:2(write)	Output parameter ID	AO:301	see Table 3-18
	40:1(read) 41:1(write)	Zero scale (0/4 mA)	AO:302	
	40:1(read) 41:1(write)	Full scale (20 mA)	AO:303	

NOTE

Settings you made for analog expander outputs will not be in effect until the analog expander output is globally enabled. To activate the analog expander output, set the analog expander option to the enabled state in the user selectable options setup (see Table 3-3).

Digital Inputs Allocation Registers

These registers are used to obtain or change the allocation of the instrument digital inputs.

Table 3-21 Digital Inputs Allocation Registers

Object : Var	Register contents	Object : Point	Range
40:2(read) 41:2(write)	Status inputs allocation ¹	AO:130	See Table 3-22
40:2(read) 41:2(write)	Pulse inputs allocation	AO:131	See Table 3-22
40:2(read) 41:2(write)	Not used ¹	AO:132	Reads as 0
40:2(read) 41:2(write)	External synchronization pulse allocation	AO:133	See Table 3-22

¹ Writing to these locations is ignored. No error will occur.

NOTES

1. All digital inputs that are not allocated as pulse inputs will be automatically configured as status inputs.
2. A digital input allocated for the external synchronization pulse will be automatically configured as a pulse input.

Table 3-22 Digital Inputs Allocation Mask

Bit number	Description
0	Digital input # 1 allocation status
1	Digital input # 2 allocation status
2-15	N/A (read as 0)

Bit meaning: 0 = input not allocated, 1 = input allocated to the group

Pulsing Setpoints Registers

These registers are used to obtain or change the setup of the pulsing output for any of two relays.

NOTE

Allocating a relay as a pulsing relay will unconditionally disable all setpoints associated with this relay. If a relay was manually operated or released, it will automatically revert to normal operation.

Table 3-23 Pulsing Setpoints

Relay	Registers
Relay #1	768-769
Relay #2	770-771

Table 3-24 Pulsing Setpoint Registers

Object : Var	Register contents	Object : Point	Range
40:2(read) 41:2(write)	Output parameter ID	AO:768	See Table 3-25
40:2(read) 41:2(write)	Number of unit-hours per pulse	AO:769	1-9999 for energy pulsing, otherwise write 0.
40:2(read) 41:2(write)	Output parameter ID	AO:770	See Table 3-25
40:2(read) 41:2(write)	Number of unit-hours per pulse	AO:771	1-9999 for energy pulsing, otherwise write 0.

Table 3-25 Pulsing Output Parameters

Pulsing parameter	Identifier
None	0
KWh import	1
KWh export	2
Kvarh import (inductive)	4
Kvarh export (capacitive)	5
Kvarh total (absolute)	6
KVAh	7

Relay Operation Control

These points allow the user to manually override relay operation normally operated via alarm setpoints.

NOTE

A relay allocated as a pulsing relay may not be manually operated or released. When a relay is allocated for pulsing, it automatically reverts to normal operation.

Table 3-26 Relay Operation Control Registers

Object : Var	Register Contents	Object : Point	State Range
10:2(read) 12:1(write)	Relay #1 Force operate/Force release/Normal	BO:80 CROB:80	0/1 = state OFF/ON
10:2(read) 12:1(write)	Relay #2 Force operate/Force release /Normal	BO:81 CROB:81	0/1 = state OFF/ON

The following restrictions should be noted when using object 12 to control the listed points:

- The Count byte is ignored.
- The Control Code byte is checked:
 - Pulse On , Pulse Off, Latch On, Latch Off are valid for all points; other Codes are invalid and will be rejected;
 - Clear sub-field is valid; other sub-fields are ignored.
- The On Time specifies in ms the amount of time the digital point is to be turned on. The minimal value of the On Time is 500 ms and the actual value may differ from the specified value by up to 50 ms.

- The Off Time specifies in ms the amount of time the digital point is to be turned off. The minimal value of the Off Time is 500 ms and the actual value may differ from the specified value by up to 50 ms.
- The Status byte in the response will reflect the success or failure of the control operation:
 - Request Accepted (0) will be return if the command was accepted;
 - Request not Accepted due to Formatting Errors (3) will be returned if the Control Code byte was incorrectly formatted or an invalid Code was present in the command;
 - Control Operation not Supported for this Point (4) will be returned if the Control Point was out of control.

To manually operate Relay #1, use the Direct-Operate (or SBO/Operate or Direct-Operate-No-Acknowledge) command to point 80 of the Control-Relay-Output-Block object with the Control Code value Latch On. To manually release Relay #1, use the Direct-Operate (or SBO/Operate or Direct-Operate-No-Acknowledge) command to point 80 of the Control-Relay-Output-Block object with the Control Code value Latch Off. To control Relay #2, use point 81. To revert Relay #1 or #2 to normal operation, use the Direct-Operate (or SBO/Operate or Direct-Operate-No-Acknowledge) command to the correspondent point of the Control-Relay-Output-Block object with the Control Code value Null Operation and Clear sub-field set to 1.

Pulse Counter Setup

Table 3-27 Pulse Counter Register

Counter	Setup registers (see Table 3-28)
Counter #1	832-833
Counter #2	834-835
Counter #3	836-837
Counter #4	838-839

Table 3-28 Pulse Counter Setup Registers

Object : Var	Register contents	Object : Point	Range
40:2(read) 41:2(write)	Associated digital input ID	AO:832	See Table 3-29
40:2(read) 41:2(write)	Scale factor (number of units per input pulse)	AO:833	1-9999
...
40:2(read) 41:2(write)	Associated digital input ID	AO:838	See Table 3-29
40:2(read) 41:2(write)	Scale factor (number of units per input pulse)	AO:839	1-9999

Table 3-29 Pulsing Output Parameters

Input	ID
Not allocated	0
Digital input #1	1
Digital input #2	2

Class 0 Point Assignment

These registers are used to obtain or change the assignment the DNP Read objects to the Class 0 polling response.

Table 3-30 Class 0 Assignment Register Groups

Groups	Points
Group #1	1152-1154
Group #2	1155-1157
...	...
Group #32	1245-1247

Table 3-31 Class 0 Point Assignment Setup Registers

Group	Object : Var	Register Contents	Object : Point	Range/Scale
#1	40:1(read) 41:1(write)	DNP Object and Variation	AO:1152	See Table 3-32
	40:1(read) 41:1(write)	DNP Point number	AO:1153	0 – 65535
	40:1(read) 41:1(write)	Number of the DNP points	AO:1154	≥1 if Point number is correct
#2	40:1(read) 41:1(write)	DNP Object and Variation	AO:1155	See Table 3-32
	40:1(read) 41:1(write)	DNP Point number	AO:1156	0 – 65535
	40:1(read) 41:1(write)	Number of the DNP points	AO:1157	≥1 if Point number is correct
...	
#32	40:1(read) 41:1(write)	DNP Object and Variation	AO:1245	See Table 3-32
	40:1(read) 41:1(write)	DNP Point number	AO:1246	0 – 65535
	40:1(read) 41:1(write)	Number of the DNP points	AO:1247	≥1 if Point number is correct

Table 3-32 DNP Read Objects to Assign to Class 0

No.	Object : Variation	Code	
		Hexadecimal	Decimal ¹
1	Analog Input 30:01	0x1E01	7681
2	Analog Input 30:02	0x1E02	7682
3	Analog Input 30:03	0x1E03	7683
4	Analog Input 30:04	0x1E04	7684
5	Analog Output 40:01	0x2801	10241
6	Analog Output 40:02	0x2802	10242
7	Binary Input 01:01	0x0101	257
8	Binary Input 01:02	0x0101	258
9	Binary Output 10:01 ²	0x0A01	2561
10	Binary Output Status 10:02	0x0A02	2562
11	Binary Counter 20:01	0x1401	5121
12	Binary Counter 20:02	0x1402	5122
13	Binary Counter 20:05	0x1405	5125
14	Binary Counter 20:06	0x1406	5126
15	Frozen Counter 21:01	0x1501	5377
16	Frozen Counter 21:02	0x1502	5378
17	Frozen Counter 21:05	0x1505	5381
18	Frozen Counter 21:06	0x1506	5382
19	Frozen Counter 21:09	0x1509	5385
20	Frozen Counter 21:10	0x150A	5386

¹ The decimal value is calculated as Object × 256 + Variation.

² Available starting with F/W Version 4.93.2 or later.

Example: Analog Input object 30, variation 03 is calculated as 30 × 256 + 3 = 7683.

Appendix A DNP Application Messages

The Powermeter is a DNP IED responding to external DNP Master requests. Table A-1 describes the Series PM172EH application level responses to external requests, including object variations, functions, codes and qualifiers supported by the instrument. The object and formats are detailed in the DNP Basic 4 Documentation Set.

Table A-1 Application Responses

Object		Request		Response		
Obj	Var	Description	Function Code	Qualifier Code	Function Code	Qualifier Code
01	0	Single Bit Binary Input	1	B	129	01
01	1	Single Bit Binary Input	1	A	129	C
01	2	Binary Input with Status	1	A	129	C
02	0	Binary Input Change	1	06	129	17,28
02	1	Binary Input Change without Time	1	07,08	129	17,28
02	2	Binary Input Change with Time	1	07,08	129	17,28
10	0	Binary Output	1	B	129	01
10	1	Binary Output ⁴	1	A	129	C
10	2	Binary Output Status	1	A	129	C
12	1	Control Relay Output Block	3,4,5	A	129	C
12	1	Control Relay Output Block	6	A	None	N/A
20	0	Binary Counter	1, 7,9, 8,10	B B B	129 129 129	01 N/R N/A
20	1	32-bit Binary Counter	1	A	129	C
20	2	16-bit Binary Counter	1	A	129	C
20	5	32-bit Binary Counter without flag	1	A	129	C
20	6	16-bit Binary Counter without flag	1	A	129	C
21	0	Frozen Counter	1	B	129	01
21	1	32-bit Frozen Counter				
21	2	16-bit Frozen Counter				
21	5	32-bit Frozen Counter with time of freeze				
21	6	16-bit Frozen Counter with time of freeze				
21	9	32-bit Frozen Counter without flag				
21	10	16-bit Frozen Counter without flag				
22	0	Counter Change Event	1	06	129	17
22	1	32-bit Counter Change Event without Time	1	07,08	129	17
22	2	16-bit Counter Change Event without Time	1	07,08	129	17
22	5	32-bit Counter Change Event with Time	1	07,08	129	17
22	6	16-bit Counter Change Event with Time	1	07,08	129	17
30	0	Analog Input (respond like 30:3)	1	B	129	01
30	1	32-bit Analog Input	1	A	129	C
30	2	16-bit Analog Input	1	A	129	C
30	3	32-bit Analog Input without flag	1	A	129	C
30	4	16-bit Analog Input without flag	1	A	129	C
32	0	Analog Change Event	1	06	129	17
32	1	32-bit Analog Change Event without Time	1	07,08	129	17
32	2	16-bit Analog Change Event without Time	1	07,08	129	17
32	3	32-bit Analog Change Event with Time	1	07,08	129	17
32	4	16-bit Analog Change Event with Time	1	07,08	129	17
40	0	Analog Output Status (respond like 40:1)	1	B	129	01
40	1	32-bit Analog Output Status	1	A	129	C
40	2	16-bit Analog Output Status	1	A	129	C
41	1	32-bit Analog Output Block	3,4,5	A	129	C
41	2	16-bit Analog Output Block	3,4,5	A	129	C
41	1	32-bit Analog Output Block	6	A	None	N/A
41	2	16-bit Analog Output Block	6	A	None	N/A
50	1	Time and Date ¹	1,2	A	129	C
60	1	Class 0	1	B	129	01
60	2	Class 1	1	06,07,08	129	17
60	3	Class 2	1	06,07,08	129	17

Object			Request		Response	
Obj	Var	Description	Function Code	Qualifier Code	Function Code	Qualifier Code
60	4	Class 3	1	06,07,08	129	17
80	1	Internal indication ²	2	D	129	
N/A	N/A	Cold Restart ³ (respond Obj. 52:2)	13	N/A	129	07
N/A	N/A	Delay Measurement (respond Obj. 52:2)	23	N/A	129	07

¹ For this object, the quantity specified in the request must be exactly 1 or an index of 0, as there is only one instance of this object defined in the instrument.

² For this object, the qualifier code must specify an index 7 only.

³ Respond with time object 50 variation 2 indicating time until instrument availability.

⁴ Available starting with F/W Version 4.93.2 or later.

Qualifier Hex Codes for each category:

A - 00,01,03,04,07,17,27,08,18,28

B - 06 only

C - Qualifier echo

D - 00,01,03,04,17,27,18,28

N/A - Not Available

N/R - Null Response

Appendix B DNP Device Profile

DNP3-2000	
DEVICE PROFILE DOCUMENT	
This document must be accompanied by a table having the following headings:	
Object Group	Request Function Codes Response Function Codes
Object Variation	Request Qualifiers Response Qualifiers
Object Name (optional)	
Vendor Name: SATEC Ltd.	
Device Name: Powermeter Series PM172EH	
Highest DNP Level Supported: For Requests L2 For Responses L2	Device Function: <input type="checkbox"/> Master <input checked="" type="checkbox"/> Slave
Instrument supports READ of each object using either all points (Qualifier = 6) or specific points using qualifier defined in Basic 4 Documentation Set: 00, 01, 03, 04, 07, 17, 27, 08, 18, 28. Control Relay Block requires specific parameters described in this manual. Treats range field of qualifier 07 and 08 to mean point range [0...N-1].	
Maximum Data Link Frame Size (octets): Transmitted 292 Received 292	Maximum Application Fragment Size (octets): Transmitted 2048 Received 249
Maximum Data Link Re-tries: <input checked="" type="checkbox"/> None <input type="checkbox"/> Fixed at _____ <input type="checkbox"/> Configurable, range ___ to _____	Maximum Application Layer Re-tries: <input checked="" type="checkbox"/> None <input type="checkbox"/> Configurable, range ____ to _____ (Fixed is not permitted)
Requires Data Link Layer Confirmation: <input checked="" type="checkbox"/> Never <input type="checkbox"/> Always <input type="checkbox"/> Sometimes If 'Sometimes', when? _____ <input type="checkbox"/> Configurable If 'Configurable', how? _____	
Requires Application Layer Confirmation: <input type="checkbox"/> Never <input type="checkbox"/> Always (not recommended) <input checked="" type="checkbox"/> When reporting Event Data (Slave devices only) <input type="checkbox"/> When sending multi-fragment responses (Slave devices only) <input type="checkbox"/> Sometimes If 'Sometimes', when? _____ <input type="checkbox"/> Configurable If 'Configurable', how? _____	

Device Profile Document (continued)

<p>Timeouts while waiting for:</p> <p>Data Link Confirm <input checked="" type="checkbox"/> None <input type="checkbox"/> Fixed at _____ <input type="checkbox"/> Variable <input type="checkbox"/> Configurable</p> <p>Complete Appl. Fragment <input checked="" type="checkbox"/> None <input type="checkbox"/> Fixed at _____ <input type="checkbox"/> Variable <input type="checkbox"/> Configurable</p> <p>Application Confirm <input type="checkbox"/> None <input checked="" type="checkbox"/> Fixed at <u>5 sec</u> <input type="checkbox"/> Variable <input type="checkbox"/> Configurable</p> <p>Complete Appl. Response <input checked="" type="checkbox"/> None <input type="checkbox"/> Fixed at _____ <input type="checkbox"/> Variable <input type="checkbox"/> Configurable</p> <p>Others</p> <p>Timeouts between fragments of the multi-fragment responses. Configurable: 50-500 ms (50 ms by default).</p> <hr/> <p>Attach explanation if 'Variable' or 'Configurable' was checked for any timeout</p>	
<p>Sends/Executes Control Operations:</p> <p>WRITE Binary Outputs <input checked="" type="checkbox"/> Never <input type="checkbox"/> Always <input type="checkbox"/> Sometimes <input type="checkbox"/> Configurable</p> <p>SELECT/OPERATE <input type="checkbox"/> Never <input checked="" type="checkbox"/> Always <input type="checkbox"/> Sometimes <input type="checkbox"/> Configurable</p> <p>DIRECT OPERATE <input type="checkbox"/> Never <input checked="" type="checkbox"/> Always <input type="checkbox"/> Sometimes <input type="checkbox"/> Configurable</p> <p>DIRECT OPERATE -</p> <p>NO ACK <input type="checkbox"/> Never <input checked="" type="checkbox"/> Always <input type="checkbox"/> Sometimes <input type="checkbox"/> Configurable</p> <p>Count > 1 <input checked="" type="checkbox"/> Never <input type="checkbox"/> Always <input type="checkbox"/> Sometimes <input type="checkbox"/> Configurable</p> <p>Pulse On <input type="checkbox"/> Never <input type="checkbox"/> Always <input checked="" type="checkbox"/> Sometimes^{1,4} <input type="checkbox"/> Configurable</p> <p>Pulse Off <input checked="" type="checkbox"/> Never <input type="checkbox"/> Always <input type="checkbox"/> Sometimes⁴ <input type="checkbox"/> Configurable</p> <p>Latch On <input type="checkbox"/> Never <input type="checkbox"/> Always <input checked="" type="checkbox"/> Sometimes² <input type="checkbox"/> Configurable</p> <p>Latch Off <input type="checkbox"/> Never <input type="checkbox"/> Always <input checked="" type="checkbox"/> Sometimes³ <input type="checkbox"/> Configurable</p> <p>Queue <input checked="" type="checkbox"/> Never <input type="checkbox"/> Always <input type="checkbox"/> Sometimes <input type="checkbox"/> Configurable</p> <p>Clear Queue <input type="checkbox"/> Never <input type="checkbox"/> Always <input checked="" type="checkbox"/> Sometimes⁴ <input type="checkbox"/> Configurable</p> <p>◆ Select timeout period is configurable: 2s to 30s</p> <p>¹ used to activate the <i>Reset</i> function associated with points 0 to 21</p> <p>^{2, 3, 4} used to control Relays associated with points 80 to 81</p> <p>³ used to reset the self-check alarm registers associated with points 64 to 75</p>	
<p>Reports Binary Input Change Events when no specific variation requested:</p> <p><input type="checkbox"/> Never</p> <p><input type="checkbox"/> Only time-tagged</p> <p><input type="checkbox"/> Only non-time-tagged</p> <p><input checked="" type="checkbox"/> Configurable to send both, one or the other (attach explanation)</p>	<p>Reports time-tagged Binary Input Change Events when no specific variation requested:</p> <p><input type="checkbox"/> Never</p> <p><input checked="" type="checkbox"/> Binary Input Change With Time</p> <p><input type="checkbox"/> Binary Input Change With Relative Time</p> <p><input type="checkbox"/> Configurable (attach explanation)</p>

Device Profile Document (continued)

<p>Sends Unsolicited Responses:</p> <ul style="list-style-type: none"> <input checked="" type="checkbox"/> Never <input type="checkbox"/> Configurable (attach explanation) <input type="checkbox"/> Only certain objects <input type="checkbox"/> Sometimes (attach explanation) <input type="checkbox"/> ENABLE/DISABLE UNSOLICITED Function codes supported 	<p>Sends Static Data in Unsolicited Responses:</p> <ul style="list-style-type: none"> <input checked="" type="checkbox"/> Never <input type="checkbox"/> When Device Restarts <input type="checkbox"/> When Status Flags Change <p>No other options are permitted.</p>
<p>Default Counter Object/Variation:</p> <ul style="list-style-type: none"> <input type="checkbox"/> No Counters Reported <input type="checkbox"/> Configurable (attach explanation) <input checked="" type="checkbox"/> Default Object 20 Default Variation 5 <input type="checkbox"/> Point-by-point list attached 	<p>Counters Roll Over at:</p> <ul style="list-style-type: none"> <input type="checkbox"/> No Counters Reported <input type="checkbox"/> Configurable (attach explanation) <input type="checkbox"/> 16 Bits <input type="checkbox"/> 32 Bits <input checked="" type="checkbox"/> Other Value Counters -999999999 to 999999999 (point 2) 0 to 99999999 (points 0,1,3) <input type="checkbox"/> Point-by-point list attached
<p>Sends Multi-Fragment Responses: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p>	