

Addendum

This addendum is applicable to the following document:

BG0296 Rev. A2 PNA296 Installation and Operation Manual

And to PNA296 S/N 241679

1. **Page 2**

The AC connector 9 and 10 are replaced by a terminal block and a fuse.

Fuse Type: Slow Blow 1.6A 250V 5X20MM SATEC P/N HL0017

2. **Page 3**

The 2 extra pins in the RELAYS connector are +DC and –DC measurement.

3. **Page 10**

3.1 External Power Supply

37-72VDC, 15W